

Building safety Certificate

The School building of **The Principal Ved Dhara Global School Village Dhanot P.O. Adhwani Teh. Jawalamukhi Distt. Kangra H.P.** was inspected by me with the concerned Junior Engineer. The building has neither being designed nor constructed by this department. No earthquake resistant norms have been adopted for this building. No structural drawings approved by the competent Government Agency have been produced. The structure is a Non Engineered structure. Hence the structural safety of this building cannot be ensured specially from earthquake point of view. This building is constructed in the 2017. This department will not be responsible for any type of loss of life and property etc., if this structure fails under any circumstances. However as per visual inspection the building appears to be safe at present under static loads.

Note: The School administration shall be responsible for security of the School children's in the school complex.

Place:- *Jwalamukhi*

Date:- *21.01.2025*

A
Junior Engineer,
Sub-Division J/Mukhi,
Section Bharoli .

Deena
Assistant Engineer,
Jawalamukhi Sub-Division,
HPPWD, Jawalamukhi.

C/S
Executive Engineer,
Jawalamukhi Division,
HPPWD., Jawalamukhi.